



WATER SAMPLE SITE PLAN

- 1. Address Numbers shall be reflective and minimum 4" in height.
- 2. 100' of defensible space is required around all structures.
- 3. 10' of defensible space is required on each side of driveway.
- Provide project name, project address, city, assesors parcel number, applicant name/phone number, & permit no.
- 5. Hose lay from edge of around access to any point on structure shall be 250' max.
- 6. See sheets 2A, 2B, and 2C for additional details & information

FIRE SAFETY STANDARDS DATE: JULY 27, 2017 SCALE: 1" = 75' STANDARD NO. REVISION DATE: